



RES

FIRE PROTECTION ENGINEERS

14 Cremyll, Road, Reading, Berkshire. RG1 8NQ
Telephone: 0118 950 0635 Fax: 0118 959 1167
Freephone: 0800 731 0727
E-mail: sales@extinguishers.co.uk
www.extinguishers.co.uk

CERTIFICATE OF INSPECTION

RES Systems Ltd provides a service through a quality management system which is registered with BSi Certificate Number FS 23010

No: 75535

We hereby certify that the fire extinguishing appliances as set out below have been serviced in accordance with British Standards 5306:Part3:Part8

Invoice name and address	Service address (if different)
At Label Works Ltd Beneley Yard Lang Acres Waterloo Road Wargh 2540 3DA	

Type of call *Annual Service* Date *7th Feb 2019*

Quantity	Type of extinguisher
<i>3</i>	<i>6L AFFF Foam Exst</i>
<i>3</i>	<i>2.5 CO2 Exst</i>
<i>1</i>	<i>Fire Blanket</i>

Parts and refills supplied
1 x Test
3 x Hose on
3 x SM on

Failed under test/recommendations

Apart from the non conforming extinguishers as recorded, all fire extinguishers have been inspected and serviced in accordance with BS5306:3

Customer's signature <i>[Signature]</i>	Customer's name <i>Paul Jones</i>	Engineer's signature <i>[Signature]</i>
--	--------------------------------------	--

Guidance to Clients: BS5306:Part3

Inspection by the User and Terms and Conditions see overleaf.

BS5306:3 Para 5 inspection by the user: It is recommended that the user carry out regular visual inspections of all extinguisher and fire blankets. The frequency of inspections by the user should be not less than monthly & when circumstances require, inspections should be carried out more frequently.

Customer Copy